

**CITY OF NAPLES
PURCHASING DIVISION
CITY HALL, 735 8TH STREET SOUTH
NAPLES, FLORIDA 34102
PH: 239-213-7100 FX: 239-213-7105**

ADDENDUM NUMBER 4

NOTIFICATION DATE:	BID TITLE:	BID NUMBER:	BID OPENING DATE & TIME:
03/16/18	Geothermal Cooling Water Supply and Facility Improvements	18-035	03/20/2018 2:00PM

**THE FOLLOWING INFORMATION IS HEREBY INCORPORATED INTO,
AND MADE AN OFFICIAL PART OF THE ABOVE REFERENCED BID.**

The following is an answer to a written submitted question:

1) Is there a reason why Reliable Controls was removed from the specifications?

ANSWER: The project engineer has designed a control system that provides for a new process which augments the existing HVAC systems in the building. In doing so there are certain prerequisites which must be addressed and some of these are that any new control system be able to work within the existing city reporting system via BACnet, be compatible with the control of the existing heat pumps, among others. As stated on sheet M-000 under "SUBMITTALS" any manufacturer can submit their product if there be an authorized agent of their company willing to provide the required statement under this paragraph. On this basis, no qualified manufacturer/supplier/installer is excluded. The same paragraph is under the electrical design as well on E-000.

###

IMPORTANT MESSAGE

PLEASE ACKNOWLEDGE RECEIPT OF THIS ADDENDUM ON THE BID COVER SHEET.